



Test Report: HLG-60H-24

60W Single Output Switching Power Supply

■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

Component Stress Test

■ SAFETY & E.M.C. TEST

Safety Test

E.M.C. Test

■ RELIABILITY TEST

ENVIRONMENT TEST

DESIGN VERIFY TEST

OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	CONSTANT CURRENT REGION	14.4V~24V	I/P : 230VAC O/P : CV=7.2V~11V Ta : 25°C	TEST : OK
2	RIPPLE & NOISE	V1 : 150 mVp-p (Max)	I/P : 230VAC O/P : FULL LOAD Ta : 25°C	V1 : 15.6 mVp-p (Max)
3	OUTPUT VOLTAGE ADJUST RANGE	CH1 : 22 V ~ 27 V	I/P : 230 VAC I/P : 115 VAC O/P : MIN LOAD Ta : 25°C	21.461 V ~ 28.075 V/ 230 VAC 21.468 V ~ 28.075 V/ 115 VAC
4	CURRENT ADJUST RANGE	CH1 : 1.5A ~ 2.5A	I/P : 230 VAC I/P : 115 VAC O/P : MIN LOAD Ta : 25°C	1.384 A~ 2.715 A/ 230 VAC 1.384 A ~ 2.711 A/ 115 VAC
5	OUTPUT VOLTAGE TOLERANCE	V1 : 1 %~-1 % (Max)	I/P : 100 VAC / 305VAC O/P : FULL/ MIN LOAD Ta : 25°C	V1 : 0.21 %~-0.21 %
6	LINE REGULATION	V1 : 0.5 %~-0.5 % (Max)	I/P : 100VAC ~ 305VAC O/P : FULL LOAD Ta : 25°C	V1 : 0.05 %~-0.05 %
7	LOAD REGULATION	V1 : 0.5 %~-0.5 % (Max)	I/P : 230 VAC O/P : FULL ~MIN LOAD Ta : 25°C	V1 : 0.21 %~-0.21 %
8	SET UP TIME	230VAC : 500 ms (Max) 115VAC : 500 ms(Max)	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/ 356 ms 115VAC/ 303 ms
9	RISE TIME	230VAC : 80 ms (Max) 115VAC : 80 ms (Max)	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/ 15 ms 115VAC/ 16 ms
10	HOLD UP TIME	230VAC : 16 ms (TYP) 115VAC : 16 ms (TYP)	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/ 76 ms 115VAC/ 41 ms
11	OVER/UNDERSHOOT TEST	< ±5%	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	TEST : <5 %
12	DYNAMIC LOAD	V1 : 2400 mVp-p	I/P : 230 VAC (1).O/P : FULL /Min LOAD 90%DUTY/ 1KHZ (2).O/P : FULL /Min LOAD 50%DUTY/ 120HZ Ta : 25°C	(1)146 mVp-p (2)1341 mVp-p

13

DIMMER TEST
(for B-type only)

SPEC:

*Reference resistance value for output current adjustment (Typical)

Resistance value	10K	20K	30K	40K	50K	60K	70K	80K	90K	100K
Output current	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%

*1 ~ 10V dimming function for output current adjustment (Typical)

Dimming value	1V	2V	3V	4V	5V	6V	7V	8V	9V	10V
Output current	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%

*10V PWM signal for output current adjustment (Typical)

Duty value	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Output current	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%

TEST RESULT: I/P : 230 VAC ;Ta : 25℃

1	Resistance value	10K	20K	30K	40K	50K	60K	70K	80K	90K	100K
	Output current	0.223A	0.480A	0.748A	1.011A	1.274A	1.546A	1.800A	2.008A	2.364A	2.502A
	%	8.92%	19.20%	29.92%	40.44%	50.96%	61.84%	72.00%	80.32%	94.56%	100.08%
2	Dimming value	1V	2V	3V	4V	5V	6V	7V	8V	9V	10V
	Output current	0.222A	0.480A	0.734A	0.991A	1.247A	1.504A	1.762A	2.016A	2.273A	2.503A
	%	8.88%	19.20%	29.36%	39.64%	49.88%	60.16%	70.48%	80.64%	90.92%	100.12%
3	Duty value	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
	Output current	0.291A	0.576A	0.841A	1.099A	1.347A	1.586A	1.817A	2.044A	2.271A	2.493A
	%	11.64%	23.04%	33.64%	43.96%	53.88%	63.44%	72.68%	81.76%	90.84%	99.72%

INPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	INPUT VOLTAGE RANGE	90VAC~305 VAC	I/P : TESTING O/P : FULL LOAD Ta : 25°C	71 V~305V TEST : OK
			I/P : LOW-LINE-3V= 87 V HIGH-LINE+10V=315 V O/P : FULL/MIN LOAD ON : 30 Sec . OFF : 30 Sec 10MIN (AC POWER ON/OFF NO DAMAGE)	
2	INPUT FREQUENCY RANGE	47HZ ~63 HZ NO DAMAGE	I/P : 90 VAC ~ 305 VAC O/P : FULL~MIN LOAD Ta : 25°C	TEST : OK
3	POWER FACTOR	0.95 / 230 VAC(TYP) 0.98 / 115 VAC(TYP) 0.92 / 277 VAC(TYP)	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	PF= 0.968 / 230 VAC PF= 0.998 / 115 VAC PF= 0.9361 / 277 VAC
4	EFFICIENCY	89.5% (TYP)	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	89.56 %
5	INPUT CURRENT	277V/ 0.3 A (TYP) 230V/ 0.32 A (TYP) 115V/ 0.64 A (TYP)	I/P : 277 VAC I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	I = 0.256 A/ 277 VAC I = 0.30 A/ 230 VAC I = 0.589 A/ 115 VAC
6	INRUSH CURRENT	230V/ 55 A (TYP) COLD START	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	I = 58 A/ 230 VAC
7	LEAKAGE CURRENT	< 0.75 mA / 277 VAC	I/P : 277 VAC O/P : Min LOAD Ta : 25°C	L-FG : 0.22 mA N-FG : 0.20 mA
8	TOTAL HARMONIC DISTORTION	THD< 20% when output loading ≥ 60% at 115VAC/230VAC input and output loading ≥ 75% at 277VAC input	I/P : 115 VAC I/P : 230 VAC O/P : 60% LOAD I/P : 277 VAC O/P : 75%LOAD Ta : 25°C	THD : 7.07 /115VAC THD : 15.87 /230VAC THD : 13.3 /277VAC

PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	OVER LOAD PROTECTION	95 % ~ 108 %	I/P : 230 VAC I/P : 115 VAC O/P : TESTING Ta : 25°C	105 %/ 230 VAC 105 %/ 115 VAC Constant current limiting, recovers automatically after fault condition is removed
2	OVER VOLTAGE PROTECTION	CH1 : 28 V ~ 35 V	I/P : 230 VAC I/P : 115 VAC O/P : MIN LOAD Ta : 25°C	30.43 V/ 230 VAC 30.10 V/ 115 VAC Shut down o/p voltage, re-power on to recover
3	OVER TEMPERATURE PROTECTION	NO DAMAGE	I/P : 230 VAC O/P : FULL LOAD	O.T.P. Active Shut down o/p voltage, re-power on to recover
4	SHORT PROTECTION	SHORT EVERY OUTPUT 1 HOUR NO DAMAGE	I/P : 305 VAC O/P : FULL LOAD Ta : 25°C	NO DAMAGE Hiccup mode, recovers automatically after fault condition is removed

COMPONENT STRESS TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	Power Transistor (D to S) or (C to E) Peak Voltage	Q 1 Rated : 10A/600V	I/P : High-Line +3V = 308 V O/P : (1)Full Load Turn on (2) Output Short (3)Full load continue Ta : 25°C	(1) 512 V (2) 496 V (3) 492 V
2	Diode Peak Voltage	D101 Rated : 30A/150V	I/P : High-Line +3V = 308 V O/P : (1)Full Load Turn on (2)Output Short (3)Full load continue Ta : 25°C	(1) 110 V (2) 106 V (3) 108 V
3	Clamp Diode Peak Voltage	D2 Rated : 2A/800V	I/P : High-Line +3V = 308 V O/P : (1) Dynamic Load 90%Duty/1KHz (2)Full load continue Ta : 25°C	(1) 628 V (2) 632 V
4	Input Capacitor Voltage	C 5 Rated : 47u/450V	I/P : High-Line +3V = 308 V O/P : (1)Full Load Turn on /Off (2) Min load Turn on /Off (3)Full Load /Min load Change Ta : 25°C	(1) 432.22 V (2) 436.68 V (3) 434.85 V
5	Control IC Voltage Test	U1 Rated : 11V~30V	I/P : High-Line +3V = 308 V O/P : (1)Full Load Turn on /Off (2) Min load Turn on /Off (3)Full Load /Min load Change Ta : 25°C	(1) 21.598 V (2) 21.492 V (3) 21.495 V
6	Power Transistor (D to S) or (C to E) Peak Voltage	Q3 Rated : 10A/700V	I/P : High-Line +3V = 308 V O/P : (1)Full Load Turn on (2) Output Short (3)Full load continue Ta : 25°C	(1) 676 V (2) 548 V (3) 688 V

■ SAFETY & E.M.C. TEST

SAFETY TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	WITHSTAND VOLTAGE	I/P-O/P : 3.75 KVAC/min I/P-FG : 2KVAC/min<4.5mA O/P-FG : 1.5 KVAC/min	I/P-O/P : 4 KVAC/min I/P-FG : 2.4KVAC/min O/P-FG : 1.8 KVAC/min Ta : 25°C	I/P-O/P : 2.343 mA I/P-FG : 2.426 mA O/P-FG : 0.527 mA NO DAMAGE
2	ISOLATION RESISTANCE	I/P-O/P : 500VDC>100MΩ I/P-FG : 500VDC>100MΩ O/P-FG : 500VDC>100MΩ	I/P-O/P : 500 VDC I/P-FG : 500 VDC O/P-FG : 500 VDC Ta : 25°C /70%RH	I/P-O/P : 30 GΩ I/P-FG : 30 GΩ O/P-FG : 30 GΩ NO DAMAGE
3	GROUNDING CONTINUITY	FG(PE) TO CHASSIS OR TRACE < 100 mΩ	40 A / 2min Ta : 25°C / 70%RH	9 mΩ

E.M.C TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	HARMONIC	EN61000-3-2 CLASS A CLASS C	I/P: 230VA50HZ O/P:100% ELECTRONIC LOAD O/P:100%/LED LOAD Ta:25°C	PASS
2	CONDUCTION	EN55015 CLASS B	I/P: 230 VAC (50HZ) O/P:FULL LOAD Ta:25°C	PASS Test by certified Lab
3	RADIATION	EN55015 CLASS B	I/P: 230 VAC (50HZ) O/P:FULL LOAD Ta:25°C	PASS Test by certified Lab
4	E.S.D	EN61000-4-2 INDUSTRY AIR:8KV / Contact:4KV	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A
5	E.F.T	EN61000-4-4 INDUSTRY INPUT: 2KV	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A
6	SURGE	IEC61000-4-5 INDUSTRY L-N :2KV L,N-PE:4KV	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A
7	Test by certified Lab & Test Report Prepare. Any contradictions of the test results, please refer to the latest EMC test report.			

RELIABILITY TEST

ENVIRONMENT TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT																																																																												
1	TEMPERATURE RISE TEST	MODEL : HLG-60H-24 1. ROOM AMBIENT BURN-IN : 1.5 HRS I/P : 230VAC O/P : 95% LOAD Ta= 28 ℃ 2. HIGH AMBIENT BURN-IN : 1 HRS I/P : 230VAC O/P : 95% LOAD Ta= 68.5 ℃ <table><thead><tr><th>NO</th><th>Position</th><th>ROOM AMBIENT Ta= 28 ℃</th><th>HIGH AMBIENT Ta=68.5℃</th></tr></thead><tbody><tr><td>1</td><td>BD1</td><td>49.4℃</td><td>85.5℃</td></tr><tr><td>2</td><td>LF2</td><td>48.2℃</td><td>84.5℃</td></tr><tr><td>3</td><td>L1</td><td>49.0℃</td><td>85.4℃</td></tr><tr><td>4</td><td>L3</td><td>48.6℃</td><td>85.1℃</td></tr><tr><td>5</td><td>C10</td><td>47.9℃</td><td>84.4℃</td></tr><tr><td>6</td><td>Q1</td><td>50.6℃</td><td>87.3℃</td></tr><tr><td>7</td><td>Q3</td><td>58.1℃</td><td>97.2℃</td></tr><tr><td>8</td><td>U1</td><td>50.8℃</td><td>87.6℃</td></tr><tr><td>9</td><td>RTH2</td><td>47.9℃</td><td>83.9℃</td></tr><tr><td>10</td><td>D2</td><td>56.8℃</td><td>95.5℃</td></tr><tr><td>11</td><td>C5</td><td>49.2℃</td><td>85.3℃</td></tr><tr><td>12</td><td>C16</td><td>48.9℃</td><td>85.0℃</td></tr><tr><td>13</td><td>T1</td><td>56.6℃</td><td>93.5℃</td></tr><tr><td>14</td><td>D101</td><td>54.7℃</td><td>91.4℃</td></tr><tr><td>15</td><td>C106</td><td>52.4℃</td><td>89.1℃</td></tr><tr><td>16</td><td>C203</td><td>47.6℃</td><td>84.0℃</td></tr><tr><td>17</td><td>LF100</td><td>49.1℃</td><td>86.0℃</td></tr><tr><td>18</td><td>C111</td><td>48.7℃</td><td>85.7℃</td></tr></tbody></table>			NO	Position	ROOM AMBIENT Ta= 28 ℃	HIGH AMBIENT Ta=68.5℃	1	BD1	49.4℃	85.5℃	2	LF2	48.2℃	84.5℃	3	L1	49.0℃	85.4℃	4	L3	48.6℃	85.1℃	5	C10	47.9℃	84.4℃	6	Q1	50.6℃	87.3℃	7	Q3	58.1℃	97.2℃	8	U1	50.8℃	87.6℃	9	RTH2	47.9℃	83.9℃	10	D2	56.8℃	95.5℃	11	C5	49.2℃	85.3℃	12	C16	48.9℃	85.0℃	13	T1	56.6℃	93.5℃	14	D101	54.7℃	91.4℃	15	C106	52.4℃	89.1℃	16	C203	47.6℃	84.0℃	17	LF100	49.1℃	86.0℃	18	C111	48.7℃	85.7℃
NO	Position	ROOM AMBIENT Ta= 28 ℃	HIGH AMBIENT Ta=68.5℃																																																																													
1	BD1	49.4℃	85.5℃																																																																													
2	LF2	48.2℃	84.5℃																																																																													
3	L1	49.0℃	85.4℃																																																																													
4	L3	48.6℃	85.1℃																																																																													
5	C10	47.9℃	84.4℃																																																																													
6	Q1	50.6℃	87.3℃																																																																													
7	Q3	58.1℃	97.2℃																																																																													
8	U1	50.8℃	87.6℃																																																																													
9	RTH2	47.9℃	83.9℃																																																																													
10	D2	56.8℃	95.5℃																																																																													
11	C5	49.2℃	85.3℃																																																																													
12	C16	48.9℃	85.0℃																																																																													
13	T1	56.6℃	93.5℃																																																																													
14	D101	54.7℃	91.4℃																																																																													
15	C106	52.4℃	89.1℃																																																																													
16	C203	47.6℃	84.0℃																																																																													
17	LF100	49.1℃	86.0℃																																																																													
18	C111	48.7℃	85.7℃																																																																													
2	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOUR	I/P : 305VAC/100VAC O/P : 95% LOAD Ta= -40℃ / -25	TEST : OK																																																																												
3	HIGH HUMIDITY HIGH TEMPERATURE HIGH VOLTAGE TURN ON TEST	AFTER 12 HOURS IN CHAMBER ON CONTROL 60 ℃ NO DAMAGE	I/P : 305 VAC O/P : 95% LOAD Ta= 60 ℃ HUMIDITY= 95 %R.H	TEST : OK																																																																												
4	TEMPERATURE COEFFICIENT	± 0.03 %(0~50℃)	I/P : 230 VAC O/P : 95% LOAD	± 0.006 %(0~50℃)																																																																												
5	STORAGE TEMPERATURE TEST	1. Thermal shock Temperature : -45℃~ +90℃ 2. Temperature change rate : 25℃ / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 5 CYCLE 5. Input/Output condition : STATIC		OK																																																																												
6	THERMAL SHOCK TEST	1. Thermal shock Temperature : -45℃~ +65℃ 2. Temperature change rate : 25℃ / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 10 CYCLE 5. Input/Output condition : 230VAC/Full Load AC ON/OFF TEST turn on 58sec ; turn off 2sec		OK																																																																												

7	VIBRATION TEST	1 Carton & 1 Set (1) Waveform : Sine Wave (2) Frequency : 10~500Hz (3) Sweep Time : 12min/sweep cycle (4) Acceleration : 5G (5) Test Time : 72min in each axis (X.Y.Z) (6) Ta : 25°C	TEST : OK
8	CAPACITOR LIFE CYCLE	HLG-60H-24 :SUPPOSE C106 IS THE MOST CRITICAL COMPONENT (1) I/P : 230VAC O/P : FULL LOAD Tc=75 °C LIFE TIME (2) I/P : 230VAC O/P : 75% LOAD Tc= 75 °C LIFE TIME (3) I/P : 230VAC O/P : 50% LOAD Tc= 75 °C LIFE TIME	(1) 57341 HRS (2) 70788 HRS (3) 83833 HRS
9	MTBF	MIL-HDBK-217F NOTICES2 PARTS COUNT TOTAL FAILURE RATE : 338K HRS	
10	Ongoing Reliability Test	I/P : 230VAC O/P : FULL LOAD TA=50°C Demonstration Mean Time Between Failure : 62,000 hours	

DATE	SAMPLE	TEST RESULT	TESTER	APPROVAL
2011/5/3	PRODUCT SAMPLE	PASS	SANFORD SU	VINCENT TSENG

2009/08/04 A50-F023