



Test Report : PWM-40-48

40W PWM Output LED Power Supply

■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

Component Stress Test

■ SAFETY & E.M.C. TEST

Safety Test

E.M.C. Test

■ RELIABILITY TEST

ENVIRONMENT TEST

■ DESIGN VERIFY TEST

OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	PWM FREQUENCY	1.47KHz	I/P: 230 VAC O/P:FULL LOAD Ta:25℃	1.483KHz	PASS
2	OUTPUT VOLTAGE TOLERANCE	V1: -1.0%~+1.0% (Max)	I/P: 90 VAC / 305VAC O/P:FULL/ NO LOAD Ta:25℃	V1: -0.027% ~ 0.087%	PASS
3	SET UP TIME	230VAC : 500 ms (Max) 115VAC : 500 ms (Max)	I/P: 230 VAC I/P: 115 VAC O/P:95% LOAD Ta:25℃	230VAC/ 344 ms 115VAC/ 350 ms	PASS
4	RISE TIME	230VAC : 80 ms (Max) 115VAC : 80 ms (Max)	I/P: 230 VAC I/P: 115 VAC O/P:95% LOAD Ta:25℃	230VAC/ 0.80 ms 115VAC/ 0.88 ms	PASS
5	HOLD UP TIME	230VAC : 16 ms (Typ) 115VAC : 16 ms (Typ)	I/P: 230 VAC I/P: 115 VAC O/P:FULL LOAD Ta:25℃	230VAC/ 32 ms 115VAC/ 20 ms	PASS
6	OVER/UNDERSHOOT TEST	< ±5%	I/P: 230 VAC O/P:FULL LOAD Ta:25℃	TEST: <5 %	PASS

7

DIMMER TEST

SPEC:

*The duty of the PWM style output can be adjusted through output cable by connecting a 0~10Vdc or 10V PWM signal or resistance between DIM+ and DIM - .

* Reference resistance value for output current adjustment (Typical)

Resistance value	10K	20K	30K	40K	50K	60K	70K	80K	90K	100K
Output duty	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%

*0 ~ 10V dimming function for output current adjustment (Typical)

Dimming value	1V	2V	3V	4V	5V	6V	7V	8V	9V	10V
Output duty	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%

*10V PWM signal for output current adjustment (Typical): Frequency range: 100Hz~3KHz

Duty value	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Output duty	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%

TEST RESULT: I/P : 230 VAC ;Ta : 25℃

1	Resistance value	10K	20K	30K	40K	50K	60K	70K	80K	90K	100K
	Output Current	0.094A	0.182A	0.270A	0.354A	0.439A	0.525A	0.612A	0.691A	0.771A	0.851A
	%	11.19%	21.67%	32.14%	42.14%	52.26%	62.50%	72.86%	82.26%	91.79%	101.31%
2	Dimming value	1V	2V	3V	4V	5V	6V	7V	8V	9V	10V
	Output Current	0.089A	0.174A	0.257A	0.346A	0.435A	0.529A	0.616A	0.709A	0.801A	0.888A
	%	10.60%	20.71%	30.60%	41.19%	51.79%	62.98%	73.33%	84.40%	95.36%	105.71%
3	Duty value	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
	Output Current	0.089A	0.170A	0.257A	0.346A	0.439A	0.529A	0.616A	0.708A	0.803A	0.888A
	%	10.60%	20.24%	30.60%	41.19%	52.26%	62.98%	73.33%	84.29%	95.60%	105.71%

PASS

INPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	INPUT VOLTAGE RANGE	90 VAC~305 VAC	I/P : TESTING O/P : FULL LOAD Ta : 25°C	87 V~305 V	PASS
			I/P : (1)LOW-LINE-3V=87 V HIGH-LINE+10V=315 V O/P : FULL/NO LOAD ON : 30 Sec OFF : 30 Sec 10MIN (2)230VAC ON : 0.5 Sec OFF : 0.5 Sec 20MIN (3)230VAC ON : 3Sec OFF : 3Sec 12HOURS (POWER ON/OFF NO DAMAGE)	TEST : (1) OK (2) OK (3) OK	
2	INPUT FREQUENCY RANGE	47HZ ~63 HZ NO DAMAGE OSC	I/P : 90 VAC ~ 305 VAC O/P : FULL ~NO LOAD Ta : 25°C	TEST : OK	PASS
3	POWER FACTOR	115V/ 0.97 (TYP) 230V/ 0.95 (TYP) 277V/ 0.92 (TYP)	I/P : 115 VAC I/P : 230 VAC I/P : 277 VAC O/P : FULL LOAD Ta : 25°C	PF= 0.996 / 115 VAC PF= 0.978 / 230 VAC PF= 0.947 / 277 VAC	PASS
4	EFFICIENCY	90% (TYP)	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	90.13%	PASS
5	INPUT CURRENT	115V/ 0.6 A (TYP) 230V/ 0.3 A (TYP) 277V/ 0.25 A (TYP)	I/P : 115 VAC I/P : 230 VAC I/P : 277 VAC O/P : FULL LOAD Ta : 25°C	I = 0.395 A/ 115 VAC I = 0.200 A/ 230 VAC I = 0.172 A/ 277 VAC	PASS
6	INRUSH CURRENT	230V/ 50 A (TYP) Twidth =270 us measured at 50% Ipeak COLD START	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	I = 38.3 A Twidth = 244 us	PASS
7	LEAKAGE CURRENT	< 0.25 mA/ 277 VAC	I/P : 305 VAC O/P : NO LOAD Ta : 25°C	L-CASE : 0.003 mA N-CASE : 0.003 mA	PASS
8	NO LOAD CONSUMPTION	< 0.5 W	I/P : 230VAC O/P : NO LOAD Ta : 25°C	0.42 W	PASS
9	TOTAL HARMONIC DISTORTION	Total harmonic distortion will be lower than 20% when output loading is 60% or higher at 230V/115VAC Total harmonic distortion will be lower than 20% when output loading is 75% or higher at 277VAC	I/P : 115 VAC I/P : 230 VAC O/P : 60% LOAD I/P : 277 VAC O/P : 75%LOAD Ta : 25°C	THD : 6.59% /115VAC THD : 15.28% /230VAC THD : 15.25% /277VAC	PASS

PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	OVER LOAD PROTECTION	108% ~ 120 %	I/P : 100 VAC I/P : 230 VAC I/P : 305 VAC O/P : TESTING Ta : 25°C	116.1 %/ 100 VAC 116.1 %/ 230 VAC 116.1 %/ 305 VAC Hiccup Mode , recovers automatically after fault condition is removed	PASS
2	OVER VOLTAGE PROTECTION	CH1 : 54 V ~ 60 V	I/P : 90 VAC I/P : 230 VAC I/P : 305 VAC O/P : NO LOAD Ta : 25°C	57.26 V/ 90 VAC 57.22 V/ 230 VAC 57.21 V/ 305 VAC Shut down o/p voltage , re-power on to recover	PASS
3	OVER TEMPERATURE PROTECTION	SPEC : O.T.P. NO DAMAGE	I/P : 230 VAC O/P : FULL LOAD	O.T.P. Active Shut down o/p voltage , re-power on to recover	PASS
4	SHORT PROTECTION	SHORT EVERY OUTPUT 1 HOUR NO DAMAGE	I/P : 305 VAC O/P : FULL LOAD Ta : 25°C	NO DAMAGE Hiccup mode , recovers automatically after fault condition is removed	PASS

COMPONENT STRESS TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	Power Transistor (D to S) or (C to E) Peak Voltage	Q2 Rated 800 V 9 A	I/P : High-Line +3V = 308 V O/P : (1) FULL LOAD Turn on (2) Output Short (3) FULL LOAD continue Ta : 25°C	(1) 610 V (2) 610 V (3) 604 V	PASS
2	Diode Peak Voltage	D100 Rated 300 V 20 A Q105 100 V 62 A	I/P : High-Line +3V = 308 V O/P : (1) FULL LOAD Turn on (2) Output Short (3) FULL LOAD continue Ta : 25°C	D100 (1) 204 V (2) 205 V (3) 203 V Q105 (1) 47.0 V (2) 49.2 V (3) 0 V	PASS
3	Input Capacitor Voltage	C5 Rated 33uF / 450 V	I/P : High-Line +3V = 308 V O/P : (1) FULL LOAD Turn on / Off (2) NO LOAD Turn on / Off (3) FULL LOAD / NO LOAD Change Ta : 25°C	(1) 446 V (2) 448 V (3) 446 V	PASS
4	Control IC Voltage Test	U1 Rated 28V	I/P : High-Line +3V = 308 V O/P : (1) FULL LOAD Turn on / Off (2) NO LOAD Turn on / Off (3) FULL LOAD / NO LOAD Change Ta : 25°C	(1) 17.3 V (2) 17.3 V (3) 17.3 V	PASS
5	PFC Transistor (D to S) or (C to E) Peak Voltage	Q1 Rated 600 V 10 A	I/P : High-Line +3V = 308 V O/P : (1) FULL LOAD Turn on (2) Output Short (3) FULL LOAD continue Ta : 25°C	(1) 462 V (2) 466 V (3) 462 V	PASS

SAFETY & E.M.C. TEST

SAFETY TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	WITHSTAND VOLTAGE	I/P-O/P : 3.75 KVAC/min	I/P-O/P : 4.2 KVAC/min Ta : 25°C	I/P-O/P : 2.647 mA NO DAMAGE	PASS
2	ISOLATION RESISTANCE	I/P-O/P : 500VDC>100MΩ	I/P-O/P : 500 VDC Ta : 25°C/70%RH	I/P-O/P : >9999 MΩ NO DAMAGE	PASS

E.M.C TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	HARMONIC	EN61000-3-2 CLASS C	I/P : 115VAC/230VAC/50HZ O/P : 60%/FULL LOAD I/P : 277VAC/50HZ O/P : 75%/FULL LOAD Ta:25°C	OK	PASS
2	CONDUCTION	EN55015 CLASS B	I/P : 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	OK Test by certified Lab	PASS
3	RADIATION	EN55015 CLASS B	I/P : 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	OK Test by certified Lab	PASS
4	E.S.D	EN61000-4-2 LIGHT INDUSTRY AIR:8KV / Contact:4KV	I/P : 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A	PASS
5	E.F.T	EN61000-4-4 LIGHT INDUSTRY INPUT : 1KV	I/P : 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A	PASS
6	SURGE	IEC61000-4-5 INDUSTRY L-N :2KV	I/P : 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A	PASS
7	Test by certified Lab & Test Report Prepare				

RELIABILITY TEST

ENVIRONMENT TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT																																																																
1	TEMPERATURE RISE TEST	MODEL : PWM-40-48 1. ROOM AMBIENT BURN-IN : 2 HRS I/P : 230VAC O/P : FULL LOAD Ta=28.4 °C 2. HIGH AMBIENT BURN-IN : 2 HRS I/P : 230VAC O/P : FULL LOAD Ta=49.5 °C <table><tr><th>NO</th><th>Position</th><th>ROOM AMBIENT Ta= 28.4 °C</th><th>HIGH AMBIENT Ta= 49.5 °C</th></tr><tr><td>1</td><td>C11</td><td>48.8°C</td><td>68.1°C</td></tr><tr><td>2</td><td>D6</td><td>51.1°C</td><td>70.2°C</td></tr><tr><td>3</td><td>Q1</td><td>52.7°C</td><td>72.0°C</td></tr><tr><td>4</td><td>Q2</td><td>55.1°C</td><td>74.2°C</td></tr><tr><td>5</td><td>C5</td><td>50.8°C</td><td>69.6°C</td></tr><tr><td>6</td><td>T1</td><td>55.9°C</td><td>74.4°C</td></tr><tr><td>7</td><td>C45</td><td>49.9°C</td><td>68.6°C</td></tr><tr><td>8</td><td>U1</td><td>49.9°C</td><td>69.2°C</td></tr><tr><td>9</td><td>C105</td><td>49.1°C</td><td>68.0°C</td></tr><tr><td>10</td><td>D100</td><td>49.1°C</td><td>67.9°C</td></tr><tr><td>11</td><td>Q105</td><td>46.5°C</td><td>65.5°C</td></tr><tr><td>12</td><td>U100</td><td>47.3°C</td><td>66.3°C</td></tr><tr><td>13</td><td>C112</td><td>43.0°C</td><td>62.4°C</td></tr><tr><td>14</td><td>RTH2</td><td>48.7°C</td><td>67.6°C</td></tr><tr><td>15</td><td>TC</td><td>44.1°C</td><td>63.8°C</td></tr></table>			NO	Position	ROOM AMBIENT Ta= 28.4 °C	HIGH AMBIENT Ta= 49.5 °C	1	C11	48.8°C	68.1°C	2	D6	51.1°C	70.2°C	3	Q1	52.7°C	72.0°C	4	Q2	55.1°C	74.2°C	5	C5	50.8°C	69.6°C	6	T1	55.9°C	74.4°C	7	C45	49.9°C	68.6°C	8	U1	49.9°C	69.2°C	9	C105	49.1°C	68.0°C	10	D100	49.1°C	67.9°C	11	Q105	46.5°C	65.5°C	12	U100	47.3°C	66.3°C	13	C112	43.0°C	62.4°C	14	RTH2	48.7°C	67.6°C	15	TC	44.1°C	63.8°C	PASS
NO	Position	ROOM AMBIENT Ta= 28.4 °C	HIGH AMBIENT Ta= 49.5 °C																																																																		
1	C11	48.8°C	68.1°C																																																																		
2	D6	51.1°C	70.2°C																																																																		
3	Q1	52.7°C	72.0°C																																																																		
4	Q2	55.1°C	74.2°C																																																																		
5	C5	50.8°C	69.6°C																																																																		
6	T1	55.9°C	74.4°C																																																																		
7	C45	49.9°C	68.6°C																																																																		
8	U1	49.9°C	69.2°C																																																																		
9	C105	49.1°C	68.0°C																																																																		
10	D100	49.1°C	67.9°C																																																																		
11	Q105	46.5°C	65.5°C																																																																		
12	U100	47.3°C	66.3°C																																																																		
13	C112	43.0°C	62.4°C																																																																		
14	RTH2	48.7°C	67.6°C																																																																		
15	TC	44.1°C	63.8°C																																																																		
2	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOUR	I/P : 305VAC/100VAC O/P : FULL LOAD Ta= -45°C/-30°C	TEST : OK	PASS																																																																
3	HIGH HUMIDITY HIGH TEMPERATURE HIGH VOLTAGE TURN ON TEST	AFTER 12 HOURS IN CHAMBER ON CONTROL 50°C NO DAMAGE	I/P : 315 VAC O/P : FULL LOAD Ta= 50°C HUMIDITY= 95% R.H	TEST : OK	PASS																																																																
4	TEMPERATURE COEFFICIENT	±0.03 %(0~50°C)	I/P : 230 VAC O/P : FULL LOAD	±0.008 %(0~50°C)	PASS																																																																
5	STORAGE TEMPERATURE TEST	1. Thermal shock Temperature : -45°C~ +85°C 2. Temperature change rate : 25°C / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 5 CYCLE 5. Input/Output condition : STATIC		OK	PASS																																																																
6	THERMAL SHOCK TEST	1. Thermal shock Temperature : -45°C~ +55°C 2. Temperature change rate : 25°C / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 10 CYCLE 5. Input/Output condition : 230VAC/FULL LOAD AC ON/OFF TEST turn on 58sec : turn off 2sec		OK	PASS																																																																
7	VIBRATION TEST	1 Carton & 1 Set (1) Waveform : Sine Wave (2) Frequency : 10~500Hz (3) Sweep Time : 12min/sweep cycle (4) Acceleration : 5G (5) Test Time : 90min in each axis (X.Y.Z) (6) Ta : 25°C		TEST : OK	PASS																																																																

8	CAPACITOR LIFE CYCLE	PWM-40-48 : SUPPOSE C105 IS THE MOST CRITICAL COMPONENT (1) I/P : 230VAC O/P : FULL LOAD Ta=25 °C LIFE TIME (2) I/P : 230VAC O/P : FULL LOAD Ta=50 °C LIFE TIME (3) I/P : 230VAC O/P : 75% LOAD Ta=50 °C LIFE TIME (4) I/P : 230VAC O/P : 50% LOAD Ta=50 °C LIFE TIME	(1) 523244 HRS (2) 107704 HRS (3) 129931 HRS (4) 138256 HRS	PASS
9	MTBF	MIL-HDBK-217F NOTICES2 PARTS COUNT TOTAL FAILURE RATE : 270.02 KHR		PASS
10	DMTBF/Accelerated Life Test	Demonstration Mean Time Between Failure(Expected Life) : 50000 hours @ Tcase 70 °C		PASS

TEST RESULT	TESTER	REVIEW	APPROVAL
PASS	ZHANGZJ/ Cary Chen	SKY	LIUWY

2009/08/04 A50-G058