



Test Report: HEP-150-24

150W Single Output Switching Power Supply

■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

Component Stress Test

■ SAFETY & E.M.C. TEST

Safety Test

E.M.C. Test

■ RELIABILITY TEST

DESIGN VERIFY TEST

OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	RIPPLE & NOISE	V1: 150 mVp-p (Max)	I/P: 230 VAC O/P:FULL LOAD Ta:25℃	V1: 29.4 mVp-p
2	OUTPUT VOLTAGE ADJUST RANGE	CH1: 22V~27 V	I/P: 230 VAC I/P:115VAC O/P:MIN LOAD Ta:25℃	21.40 V~27.57 V /230VAC 21.45 V~27.57 V/115VAC
3	CURRENT ADJ RANGE	3.8A~6.3A	I/P: 230 VAC O/P:FULL LOAD Ta:25℃	2.83 A~ 7.99 A
4	OUTPUT VOLTAGE TOLERANCE	V1: -1 % ~ 1 % (Max)	I/P: 100 VAC /305VAC O/P:FULL/ 0 % LOAD Ta:25℃	V1: -0.18 %~ 0.18 %
5	LINE REGULATION	V1: - 0.5% ~ 0.5 % (Max)	I/P:100 VAC ~305 VAC O/P:FULL LOAD Ta:25℃	V1: 0 %~ 0 %
6	LOAD REGULATION	V1: - 0.5% ~ 0.5 % (Max)	I/P: 230 VAC O/P:FULL ~MIN LOAD Ta:25℃	V1: -0.18 %~ 0.18 %
7	SET UP TIME	230VAC/ 500 ms (Max) 115VAC/ 1000 ms (Max)	I/P: 230 VAC I/P: 115 VAC O/P:FULL LOAD Ta:25℃	230VAC/ 396 ms 115 VAC/ 826 ms
8	RISE TIME	230VAC/ 50 ms (Max) 115VAC/ 50 ms (Max)	I/P: 230 VAC I/P: 115 VAC O/P:FULL LOAD Ta:25℃	230VAC/ 7 ms 115 VAC/ 7 ms
9	HOLD UP TIME	230VAC/ 16 ms (Typ) 115VAC/ 16 ms (Typ)	I/P: 230 VAC I/P: 115 VAC O/P:FULL LOAD Ta:25℃	230VAC/ 21 ms 115 VAC/ 21 ms
10	OVER/UNDERSHOOT TEST	< ±5%	I/P: 230 VAC O/P:FULL LOAD Ta:25℃	TEST:< 5 %
11	DYNAMIC LOAD	V1: 2400 mVp-p	I/P: 230 VAC O/P:(1)FULL /Min LOAD 90%DUTY/1KHZ (2)FULL /Min LOAD 90%DUTY/120HZ Ta:25℃	712 mVp-p 1300 mVp-p

INPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	INPUT VOLTAGE RANGE	90VAC~305 VAC	I/P:TESTING O/P:FULL LOAD Ta:25°C	71 V~305V
			I/P: (1)LOW-LINE=3V=87 V (2)HIGH-LINE=305 V O/P:FULL/MIN LOAD ON: 30 Sec . OFF: 30 Sec 10MIN (AC POWER ON/OFF NO DAMAGE)	TEST: OK
2	INPUT FREQUENCY RANGE	47HZ ~63 HZ NO DAMAGE	I/P: 100 VAC ~305VAC O/P:FULL~MIN LOAD Ta:25°C	OK
3	POWER FACTOR	0.95/ 230 VAC FULL LOAD (TYP) 0.98/ 115 VAC FULL LOAD (TYP) 0.92/ 115 VAC FULL LOAD (TYP)	I/P: 230 VAC I/P: 115 VAC I/P: 277 VAC O/P:FULL LOAD Ta:25°C	PF=0.968 /230V/100%LOAD PF= 0.997 /115V/100%LOAD PF= 0.925 /277V/100%LOAD
4	EFFICIENCY	93% (TYP)	I/P: 230 VAC O/P:FULL LOAD Ta:25°C	93.83 %
5	INPUT CURRENT	277V/ 0.7 A (TYP) 230 V/ 0.75 A (TYP) 115 V/ 1.7 A (TYP)	I/P: 277 VAC I/P: 230 VAC I/P: 115 VAC O/P:FULL LOAD Ta:25°C	I = 0.63 A/ 277VAC I = 0.73 A/ 230VAC I = 1.5 A/ 115VAC
6	INRUSH CURRENT	230 V/ 65A (Typ) COLD START	I/P: 230 VAC O/P:FULL LOAD Ta:25°C	I = 59 A/ 230VAC

PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	OVER LOAD PROTECTION	105 %~125 %	I/P: 305VAC I/P: 230 VAC I/P: 100 VAC O/P:TESTING Ta:25°C	110 %/305VAC 110 %/ 230VAC 110 %//100VAC Constant current limiting, recovers automatically after fault condition is removed
2	OVER VOLTAGE PROTECTION	V1: 28V~ 34V	I/P: 305VAC I/P: 230 VAC I/P: 90 VAC O/P:MIN LOAD Ta:25°C	29.90 V/ 305VAC 30.25 V/ 230VAC 30.29 V/ 100VAC Shut down o/p voltage with auto recovery or re-power on to recovery
3	OVER TEMPERATURE PROTECTION	Shut down o/p voltage with auto recovery or re-power on to recovery	I/P: 230 VAC O/P:FULL LOAD	O.T.P. Active Shut down o/p voltage with auto recovery or re-power on to recovery
4	SHORT PROTECTION	SHORT EVERY OUTPUT 1 HOUR NO DAMAGE	I/P: 305VAC O/P: FULL LOAD Ta:25°C	NO DAMAGE Constant current limiting, recovers automatically after fault condition is removed

COMPONENT STRESS TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	Power Transistor (D to S) or (C to E) Peak Voltage	Q5 Rated 12A/500V	I/P : High-Line +3V = 308V O/P : (1)Full Load Turn on (2) Output Short (3)Full load continue Ta : 25°C	(1) 478 V (2) 450 V (3) 456 V
2	Diode Peak Voltage	Q101 Rated 80A/75V	I/P : High-Line +3V =308V O/P : (1)Full Load Turn on (2)Output Short (3)Full load continue Ta : 25°C	(1) 62.4 V (2) 13.6 V (3) 58.8 V
		Q102 Rated 80A/75V	I/P : High-Line +3V = 308 V O/P : (1)Full Load Turn on (2)Output Short (3)Full load continue Ta : 25°C	(1) 62.4 V (2) 28.6 V (3) 58.4 V
3	Input Capacitor Voltage	C5 Rated: 100u/450V	I/P : High-Line +3V = 308V O/P : (1)Full Load Turn on /Off (2) Min load Turn on /Off (3)Full Load /Min load Change Ta : 25°C	(1) 437 V (2) 437.3 V (3) 437.2 V
4	Control IC Voltage Test	U 900 Rated 8.85V~16V	I/P : High-Line +3V = 308V O/P : (1)Full Load Turn on /Off (2) Min load Turn on /Off (3)Full Load /Min load Change Ta : 25°C	(1) 12.709 V (2) 12.637 V (3) 12.632 V
5	P.F.C Transistor (D to S) or (C to E) Peak Voltage	Q1 Rated 17A/600V	I/P : High-Line +3V = 308 V O/P : (1)Full Load Turn on (2)Output Short (3)Full load continue Ta : 25°C	(1) 486 V (2) 454 V (3) 460 V

SAFETY & EMC TEST

SAFETY TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	WITHSTAND VOLTAGE	IEC60950-1 I/P-O/P: 3.75KVAC/min I/P-FG:2 KVAC/min O/P-FG:1.5KVAC/min	I/P-O/P: 4 KVAC/min I/P-FG: 2.4KVAC/min O/P-FG: 1.8KVAC/min Ta:25°C	I/P-O/P: 2.617 mA I/P-FG: 2.315 mA O/P-FG: 3.36 mA NO DAMAGE
2	ISOLATION RESISTANCE	I/P-O/P:500VDC>100MΩ I/P-FG: 500VDC>100MΩ O/P-FG:500VDC>100MΩ	I/P-O/P: 500 VDC I/P-FG: 500 VDC O/P-FG: 500 VDC Ta:25°C	I/P-O/P: 30 GΩ I/P-FG: 30 GΩ O/P-FG: 30 GΩ NO DAMAGE
3	GROUNDING CONTINUITY	IEC60950-1 FG(PE) TO CHASSIS OR TRACE < 100 mΩ	40A / 2min Ta:25°C	9 mΩ
4	LEAKAGE CURRENT	IEC60950-1 < 0.75 mA / 277VAC	I/P: 277 VAC O/P:Min LOAD Ta:25°C	L-FG: 0.27 mA N-FG: 0.27 mA

E.M.C TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	HARMONIC	EN61000-3-2 CLASS A	I/P: 240VAC/50HZ O/P:100%/50% LOAD Ta:25°C	PASS
2	CONDUCTION	EN55022 CLASS B	I/P: 230 VAC (50HZ) O/P:FULL/50% LOAD Ta:25°C	PASS Test by certified Lab
3	RADIATION	EN55022 CLASS B	I/P: 230 VAC (50HZ) O/P:FULL LOAD Ta:25°C	PASS Test by certified Lab
4	E.S.D	EN61000-4-2 LIGHT INDUSTRY AIR:8KV / Contact:4KV	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A
5	E.F.T	EN61000-4-4 LIGHT INDUSTRY INPUT : 1KV	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A
6	SURGE	IEC61000-4-5 INDUSTRY L-N : 3KV L,N-PE:6KV	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A

Reliability Test

ENVIRONMENT TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT																																																																												
1	TEMPERATURE RISE TEST	MODEL : HEP-150-24 1. ROOM AMBIENT BURN-IN : 15.5 HRS I/P : 230VAC O/P : FULL LOAD Ta= 27.8 ℃ 2. HIGH AMBIENT BURN-IN : 7 HRS I/P : 230VAC O/P : FULL LOAD Ta=57.8 ℃ <table><tr><th>NO</th><th>Position</th><th>ROOM AMBIENT Ta= 27.8 ℃</th><th>HIGH AMBIENT Ta=57.8℃</th></tr><tr><td>1</td><td>BD1</td><td>50.5℃</td><td>77.5℃</td></tr><tr><td>2</td><td>Q1</td><td>54.3℃</td><td>81.3℃</td></tr><tr><td>3</td><td>L2</td><td>56.1℃</td><td>83.1℃</td></tr><tr><td>4</td><td>Q5</td><td>55.2℃</td><td>82.2℃</td></tr><tr><td>5</td><td>D2</td><td>56.3℃</td><td>83.3℃</td></tr><tr><td>6</td><td>RTH2</td><td>51.5℃</td><td>78.5℃</td></tr><tr><td>7</td><td>T1</td><td>56.5℃</td><td>83.5℃</td></tr><tr><td>8</td><td>Q101</td><td>52.2℃</td><td>79.2℃</td></tr><tr><td>9</td><td>D9</td><td>53.1℃</td><td>80.1℃</td></tr><tr><td>10</td><td>C102</td><td>49.9℃</td><td>76.9℃</td></tr><tr><td>11</td><td>C201</td><td>50.4℃</td><td>77.4℃</td></tr><tr><td>12</td><td>C16</td><td>52.0℃</td><td>79.0℃</td></tr><tr><td>13</td><td>C106</td><td>47.9℃</td><td>74.9℃</td></tr><tr><td>14</td><td>C38</td><td>55.5℃</td><td>82.5℃</td></tr><tr><td>15</td><td>LF100</td><td>48.7℃</td><td>75.7℃</td></tr><tr><td>16</td><td>U900</td><td>52.7℃</td><td>79.7℃</td></tr><tr><td>17</td><td>U1</td><td>53.0℃</td><td>80.0℃</td></tr><tr><td>18</td><td>C5</td><td>46.4℃</td><td>76℃</td></tr></table>			NO	Position	ROOM AMBIENT Ta= 27.8 ℃	HIGH AMBIENT Ta=57.8℃	1	BD1	50.5℃	77.5℃	2	Q1	54.3℃	81.3℃	3	L2	56.1℃	83.1℃	4	Q5	55.2℃	82.2℃	5	D2	56.3℃	83.3℃	6	RTH2	51.5℃	78.5℃	7	T1	56.5℃	83.5℃	8	Q101	52.2℃	79.2℃	9	D9	53.1℃	80.1℃	10	C102	49.9℃	76.9℃	11	C201	50.4℃	77.4℃	12	C16	52.0℃	79.0℃	13	C106	47.9℃	74.9℃	14	C38	55.5℃	82.5℃	15	LF100	48.7℃	75.7℃	16	U900	52.7℃	79.7℃	17	U1	53.0℃	80.0℃	18	C5	46.4℃	76℃
NO	Position	ROOM AMBIENT Ta= 27.8 ℃	HIGH AMBIENT Ta=57.8℃																																																																													
1	BD1	50.5℃	77.5℃																																																																													
2	Q1	54.3℃	81.3℃																																																																													
3	L2	56.1℃	83.1℃																																																																													
4	Q5	55.2℃	82.2℃																																																																													
5	D2	56.3℃	83.3℃																																																																													
6	RTH2	51.5℃	78.5℃																																																																													
7	T1	56.5℃	83.5℃																																																																													
8	Q101	52.2℃	79.2℃																																																																													
9	D9	53.1℃	80.1℃																																																																													
10	C102	49.9℃	76.9℃																																																																													
11	C201	50.4℃	77.4℃																																																																													
12	C16	52.0℃	79.0℃																																																																													
13	C106	47.9℃	74.9℃																																																																													
14	C38	55.5℃	82.5℃																																																																													
15	LF100	48.7℃	75.7℃																																																																													
16	U900	52.7℃	79.7℃																																																																													
17	U1	53.0℃	80.0℃																																																																													
18	C5	46.4℃	76℃																																																																													
2	OVER LOAD BURN-IN TEST	NO DAMAGE 1 HOUR (MIN)	I/P : 305 VAC O/P : O/P SHORT TEST Ta : 25℃	TEST : OK																																																																												
3	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOUR	I/P : 305 VAC/100VAC O/P : 100% LOAD Ta= -55 ℃	TEST : OK																																																																												
4	HIGH HUMIDITY HIGH TEMPERATURE HIGH VOLTAGE TURN ON TEST	AFTER 12 HOURS IN CHAMBER ON CONTROL 60 ℃ NO DAMAGE	I/P : 305 VAC O/P : 100% LOAD Ta= 60 ℃ HUMIDITY= 95 %R.H	TEST : OK																																																																												
5	TEMPERATURE COEFFICIENT	± 0.03 %(0~60℃)	I/P : 230 VAC O/P : FULL LOAD	± 0.002%(0~60℃)																																																																												
6	STORAGE TEMPERATURE TEST	1. Thermal shock Temperature : -60℃ ~ +90℃ 2. Temperature change rate : 25℃ / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 5 CYCLE 5. Input/Output condition : STATIC.		OK																																																																												

7	THERMAL SHOCK TEST	1. Thermal shock Temperature : $-55^{\circ}\text{C} \sim +65^{\circ}\text{C}$ 2. Temperature change rate : $25^{\circ}\text{C} / \text{MIN}$ 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 10 CYCLE 5. Input/Output condition : 230VAC/Full Load TURN ON/58 SEC;TURN OFF/2 SEC.	OK
8	VIBRATION TEST	1 Carton & 1 Set (1) Waveform : Sine Wave (2) Frequency : 20~500Hz (3) Sweep Time : 12min/sweep cycle (4) Acceleration : 10G (5) Test Time : 72min in each axis (X.Y.Z) (6) Ta : 25°C	TEST : OK
9	CAPACITOR LIFE CYCLE	HEP-150-24:SUPPOSE C102 IS THE MOST CRITICAL COMPONENT (1) I/P : 230VAC O/P : FULL LOAD Ta= 25°C LIFE TIME (2) I/P : 230VAC O/P : FULL LOAD Ta= 60°C LIFE TIME (3) I/P : 230VAC O/P : 75% LOAD Ta= 60°C LIFE TIME (4) I/P : 230VAC O/P : 50% LOAD Ta= 60°C LIFE TIME	(1) 819990 HRS (2) 89216 HRS (3) 125461 HRS (4) 147312 HRS
10	MTBF	Conducted by Parts Stress Analysis Prediction 164.1K hrs min. MIL-HDBK-217F (25°C)	OK
11	DMTBF/Accelerated Life Test	Demonstration Mean Time Between Failure(Expected Life) : 55,000 hours @ Tcase 80°C	OK

TEST RESULT	TESTER	REVIEW	APPROVAL
PASS	DANIEL GAO	SANFORD SU	VINCENT TSENG

2003/12/12 A50-F023